

# Resistance to Flow Through

## Equivalent Length of Pipe Fittings & Valves

Internal Diameter	90° Long Radius Bend (radius > 3 x NB)	90° Short Radius Bend (radius > 2 x NB)	Elbow	Tee	Rubber Hose (minimum radius 10 x NB)	Diaphragm Valve Full Open	Full Bore Valve Roundway	Plug-Iub Valve Rect Way	Tech Taylor Valve Ball Type
mm	EQUIVALENT LENGTH (m) OF STRAIGHT PIPE EQUIVALENT RESISTANCE FLOW								
25	0.52	0.70	0.82	1.77	0.30	2.56	—	0.37	—
32	0.73	0.91	1.13	2.38	0.40	3.29	—	0.49	—
40	0.85	1.10	1.31	2.74	0.49	3.44	1.19	0.58	—
50	1.07	1.40	1.68	3.35	0.55	3.66	1.43	0.73	—
65	1.28	1.65	1.98	4.27	0.70	4.60	1.52	0.85	—
80	1.55	2.07	2.47	5.18	0.85	4.88	1.92	1.04	0.20
90	1.83	2.44	2.90	5.79	1.01	—	—	1.22	—
100	1.13	2.77	3.35	6.71	1.16	7.62	2.19	1.40	0.23
115	2.41	3.05	3.66	7.32	1.28	—	—	1.58	—
125	2.71	3.66	4.27	8.23	1.43	13.11	3.05	1.77	0.30
150	3.35	4.27	4.88	10.06	1.55	18.29	3.11	2.13	0.37
200	4.27	5.49	6.40	13.11	2.41	19.81	7.92	2.74	0.82
250	5.18	6.71	7.92	17.07	2.99	21.34	10.67	3.47	0.61
300	6.10	7.92	9.75	20.12	3.35	28.96	15.85	4.08	0.76
350	7.01	9.45	10.97	23.16	4.27	28.96	—	4.88	0.91
400	8.23	10.67	12.8	26.52	4.88	—	—	5.49	1.04
450	9.14	12.19	14.02	30.48	5.49	—	—	6.22	1.16
500	10.36	13.11	15.85	33.53	6.10	—	—	7.32	1.25









"Tech Taylor" Valves is a ball type changeover device used only on the delivery side of the pump.

Note: (i) For 135° bend, use 50% of equivalent length for 90° bend.

(ii) L, is the aggregate of equivalent lengths for all pipeline fittings and valves in a given pipeline.

## Head Losses at Inlet - Contraction & Enlargement

Groups 1 to 5 in table show the approximate proportions of velocity head,  $H_v = \frac{V^2}{2g}$ , which apply to certain conditions  $g = 9.81 \text{ m/s}^2$ . V is used to indicate the up stream velocity and  $V_1$  the down stream velocity.

Group	Item	Head Loss	Group	Item	Head Loss																					
<b>1</b>   	(a) Flush Connections.	$0.5 \frac{V_1^2}{2g}$	<b>3</b> 	Loss of head due to sudden contraction: $K_c$ is factor or depending on ratio $d_1/d_2$ where $d_1$ is the large diameter and $d_2$ the small diameter as illustrated below.	$K_c \frac{V_1^2}{2g}$																					
	(b) Projecting Connection and dredge suction pipes.	$1.0 \frac{V_1^2}{2g}$				<table border="1"> <tr> <td><math>d_1/d_2</math></td> <td>1.2</td> <td>1.4</td> <td>1.6</td> <td>1.8</td> <td>2.0</td> <td>2.5</td> <td>3.0</td> <td>4.0</td> <td>5.0</td> </tr> <tr> <td><math>K_c</math></td> <td>0.08</td> <td>0.17</td> <td>0.25</td> <td>0.34</td> <td>0.37</td> <td>0.41</td> <td>0.43</td> <td>0.45</td> <td>0.46</td> </tr> </table>	$d_1/d_2$	1.2	1.4	1.6	1.8	2.0	2.5	3.0	4.0	5.0	$K_c$	0.08	0.17	0.25	0.34	0.37	0.41	0.43	0.45	0.46
	$d_1/d_2$	1.2				1.4	1.6	1.8	2.0	2.5	3.0	4.0	5.0													
$K_c$	0.08	0.17	0.25	0.34	0.37	0.41	0.43	0.45	0.46																	
(c) Rounded Connection.	$0.05 \frac{V_1^2}{2g}$																									
<b>2</b> 	Loss of head due to conical enlargement from pump discharge flange to discharge pipeline.	$K_e \frac{(V - V_1)^2}{2g}$	<b>4</b> 	Loss of head due to sudden enlargement	$\frac{(V - V_1)^2}{2g}$																					
	<table border="1"> <tr> <td>included angle fl</td> <td>6°</td> <td>65°</td> </tr> <tr> <td>factor <math>K_e</math></td> <td>0.14</td> <td>1.15</td> </tr> </table> For conical enlargements, maximum head loss occurs when included angles is 65° when $K_e = 1.15$ . Minimum head loss occurs when included angles 6° when $K_e = 0.14$					included angle fl	6°	65°	factor $K_e$	0.14	1.15															
included angle fl	6°	65°																								
factor $K_e$	0.14	1.15																								
<b>5</b> 	Loss of head due to conical contraction e.g. Jet Nozzles	$K_g \frac{(V - V_1)^2}{2g}$	<b>5</b> 	Loss of head due to conical contraction e.g. Jet Nozzles	$K_g \frac{(V - V_1)^2}{2g}$																					